

ADDENDUM NO. 3

October 12, 2016

**TO: Plans and Specifications for
Stiff Creek Sewer Capital Improvements
City of Melissa, TX
H&F Project No. 01013**

**BY: H&F Consulting, Inc.
1710 Cooper St.
Melissa, Texas 75454
Phone: 972-837-2111**

**BID OPENING DATE: OCTOBER 28, 2016
BID OPENING TIME: 2:05 PM**

This Addendum is hereby made a part of the Contract Documents to the same extent as if it were originally included therein. The following modifications, clarifications, additions, or deletions shall be made to the appropriate sections of the plans and specifications and shall become a part of, and attached to, the Contract Documents.

Modifications: Ref Specification TS3 - Lift Station Specifications, Smith and Loveless Page 4, Controls. Add the following paragraph to the end of the section. "Provisions shall be made for dry contacts to interface to the City's SCADA system for the following items:

Pump 1 Run Status
Pump 2 Run Status
Pump 3 Run Status
Control Panel Alarm
Control Panel Fault
High Water"

END OF ADDENDUM NO. 3



Casey Berend
10/12/2016