

### Inorganic Contaminants

Year or Range	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Unit of Measure	Source of Contaminant
2006	Barium	0.004	0.004	0.004	2	2	ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
2006	Fluoride	0.9	0.9	0.9	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
2007	Nitrate	0.05	0.05	0.05	10	10	ppm	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
2006	Combined Radium 226 & 228	0.5	0.5	0.5	5	0	pCi/L	Erosion of natural deposits.

### Organic Contaminants TESTING WAIVED, NOT REPORTED, OR NONE DETECTED

#### Maximum Residual Disinfectant Level

Year	Disinfectant	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Source of Disinfectant
2007	Chlorine Residual, Free	1.55	0.21	4.4	4	4	ppm	Disinfectant used to control microbes.

### Disinfection Byproducts

Year	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	Unit of Measure	Source of Contaminant
2005	Total Haloacetic Acids	1.1	1.1	1.1	60	ppb	Byproduct of drinking water disinfection.

### Unregulated Initial Distribution System Evaluation for Disinfection Byproducts WAIVED OR NOT YET SAMPLED

#### Unregulated Contaminants

Year or Range	Contaminant	Average Level	Minimum Level	Maximum Level	Unit of Measure	Source of Contaminant
Bromoform, chloroform, dichlorobromomethane, and dibromochloromethane are disinfection byproducts. There is no maximum contaminant level for these chemicals at the entry point to distribution.						
2007	Chloroform	1.85	1.85	1.85	ppb	Byproduct of drinking water disinfection.
2007	Bromoform	3.38	3.38	3.38	ppb	Byproduct of drinking water disinfection.
2007	Bromodichloromethane	4.06	4.06	4.06	ppb	Byproduct of drinking water disinfection.
2007	Dibromochloromethane	4.97	4.97	4.97	ppb	Byproduct of drinking water disinfection.